

# Jail Lighting LED Retrofit Addendum #1

1. A background check is required for every person working on this project prior to entering the building, this includes but is not limited to the Contractor, their employees' and all Subs. The background will be reviewed by Sheriff's Office Staff and Tom Banks for approval.
2. Builders Risk Insurance will not be required for this project.
3. There will be around 150 medium based, 15 watts, night lights that will need to be replaced with 2 or 2.5 watt LED.
4. Who will be responsible for obtaining the permit(s)?
  - ❖ The Contractor will be responsible for applying for the permits, and Klamath County Maintenance will pay for the permits.
5. The Contractor will purchase the one hundred 8 to 10 watt Led bulbs, that will replace the 60 watt incandescent bulbs, and Klamath County Maintenance will install them.
6. All 4 foot bulbs must be the same wattage.
7. Fixtures will remain two bulb fixtures.
8. Who will be disposing of the recycle?
  - ❖ The Contractor will be responsible for boxing the recyclables, and Klamath County Maintenance will supply the boxes and dispose of the recyclables.

## NOTICE TO ALL BIDDERS AND PLANHOLDERS

The documents for the above-referenced Project are modified as set forth in this Addendum. The original documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Contract Documents. ***Bidder shall take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided on the Bid Form.***

Leslie Barlow-Hunter  
Contract and Risk Manager  
541-851-3693

Please sign and return this Addendum with your Bid.

\_\_\_\_\_  
Contractor Name

\_\_\_\_\_  
Date